

# CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI  
MAYOR

BOARD OF  
**BUILDING AND SAFETY  
COMMISSIONERS**

VAN AMBATIELOS  
PRESIDENT

E. FELICIA BRANNON  
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
JAVIER NUNEZ

DEPARTMENT OF  
**BUILDING AND SAFETY**  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

FRANK M. BUSH  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.  
EXECUTIVE OFFICER

Syntegra, LLC  
15030 Hilton Drive  
Fontana, CA 92336

Attention: Michael Phillips  
(909) 374-1108

RESEARCH REPORT: RR 26172  
(CSI # 23 07 00)

Expires: March 1, 2020  
Issued Date: March 1, 2019  
Code: 2017 LABC

## GENERAL APPROVAL – Syntegra Fire-Rated and Life-Safety Door Assemblies

### DETAILS

1. XT Series Door Systems – Steel fire door with life-safety rated integral Panic/Exit Device
  - a. Fire rated up to 3-hours - Dependent on door size and construction (See Attachments)
2. PX Series Door Systems – Steel fire door with integral pushpad egress operator
  - a. Fire rated up to 3-hours - Dependent on door size and construction (See Attachments)
3. LX Series Door Systems – Steel fire door with integral lever operators
  - a. Fire rated up to 3-hours – Dependent on door size and construction (See Attachments)

### The approval is subject to the following conditions:

1. This approval shall be limited to those Syntegra door assemblies that bear QAI labels as listed herein:
  - F420-2-1-90
  - F420-2-1-180
  - F420-2-2-180

RR 26172  
Page 1 of 2

Syntegra, LLC  
RE: Fire-Rated and Life-Safety Door Assemblies

2. Syntegra door assemblies shall be installed in accordance with the manufacturer's installation instructions, the referenced QAI listing, Los Angeles Research Report, LARR No. 26172 and the 2017 Los Angeles City Building Code.

## **DISCUSSION**

This report is in compliance with the 2017 Los Angeles City Building Code.

The approval is based on tests in accordance with the test facilities and standards referenced above.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineer and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors

---

DAVID CHANG, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone- 213-202-9812  
Fax- 213-202-9943

EB  
RR 26172  
TLB1900005  
R02/12/19  
104.6.2

Attachments:           QAI Building Products/Fire Door Listings (10 pages)